



Notes:

1. Cleanouts in hardscape shall be brought to grade and installed in a cleanout box and plugged watertight with a mechanical plug, per Standard Detail #9. Otherwise, cleanouts shall be brought to within 24" of grade and plugged watertight with a gasketed cap or push plug.
2. All pipe material shall be bell & spigot type with rubber gasket joint and shall be in conformance with ASTM D3034 (SDR-35).

**SIDE SEWER  
HOUSE CONNECTION**

NOT TO SCALE

Detail Approvals  
 Engineer GSM  
 Manager DPK

**NORTHSHORE UTILITY DISTRICT  
STANDARD SEWER DETAILS**



June 2016  
S-8b(HOUSECONNECTION).dwg