



**MATERIALS LIST**

ITEM	QUANTITY	DESCRIPTION
------	----------	-------------

- |     |   |                                                                                                                          |
|-----|---|--------------------------------------------------------------------------------------------------------------------------|
| (A) | 1 | Water Main Tee, M.J.XM.J. with 2" IPS tap and M.J. plug.                                                                 |
| (B) | 1 | 2"x6" brass nipple.                                                                                                      |
| (C) | 1 | 4"x8"x16" concrete block.                                                                                                |
| (D) | 1 | 2" ball valve, FIPxFIP, Ford #B11-777 with 2" operating nut, Ford #QT-67.                                                |
| (E) | 1 | 2"x6" galvanized iron pipe nipple.                                                                                       |
| (F) | 2 | 2" 90° galvanized elbow, FIPxFIP.                                                                                        |
| (G) | 1 | 2" galvanized iron pipe close nipple between elbows.                                                                     |
| (H) | 1 | 2" galvanized iron pipe, length to fit.                                                                                  |
| (I) | 1 | 2" galvanized coupling, FIPxFIP.                                                                                         |
| (J) | 1 | 2" PVC Plug.                                                                                                             |
| (K) | 1 | Two-Piece cast iron valve box per the Specifications and Standard Detail.                                                |
| (L) | 1 | Locator wire: 14 guage copper, continuous, solid core, neoprene coated per the Specifications. Continuous from mainline. |
| (M) | 1 | Armorcast meter box, A6001640PCX12-NUD (with no "mouse holes") and Armorcast cover, A6001947T-NUD                        |

**2" BLOW-OFF ASSEMBLY**

NOT TO SCALE

Detail Approvals	
Editor	TDC
Manager	DPK

**NORTHSHORE UTILITY DISTRICT**  
**STANDARD WATER DETAILS**

**10**

February 2017  
W-10(BlowOff).dwg